

DECLARATION OF CONFORMITY

in accordance with EN 45014:1989

Manufacturers Name: Xycom Automation Inc.

Manufacturers Address: 750 North Maple Road
Saline, MI 48176
USA.

Declares under our sole responsibility that the product:

Product name: Operator Interface Workstation

Model Series: 3112T

Product Options: This declaration covers all options of the above product which bear the CE Marking.

Is in conformity with the following standards or other normative documents:

Low-Voltage Directive 73/23/EEC: IEC 60950-1:2001, First Edition
EN 60950-1:2001

EMC Directive 89/336/EEC: EN 55022:1998+A1:2000+A2:2003, Class A, ITE EMI
EN 61000-6-2:2001, Immunity for industrial environments
EN 61000-3-2:2000, Limits for Harmonic Current Emissions
EN 61000-3-3: 1995+A1:2001, Limitation of Voltage Fluctuations and Flicker

Supplementary Information:

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC (and amending directive 93/68/EEC), and the EMC Directive 89/336/EEC (and amending directives 91/263/EEC, 92/31/EEC, 93/68/EEC).

The XYCOM model 3112T operator interface workstation was tested for EMC compliance with the Touch Screen option installed and as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, USA.

15-Apr-05



Location

**Issue
Date**

**Margaret R. Murdock
Director of Engineering**

European Contact:

Pro-face UK, Ltd., Pro-Face House, Orchard Court, Binley Business Park, COVENTRY, UK, CV3 2TQ
Tel: +44 (0)2476 440088, Fax: +44 (0)2476 440099
Web: <http://www.profaceuk.com>, E-mail: info@profaceuk.com