

DECLARATION OF CONFORMITY

Manufacturers Name: XYCOM Inc.

Manufacturers Address: 750 North Maple Road
Saline, MI 48176
U.S.A.

Declares that the product:

Product name: Operator Interface Workstation

Model Number: 3200MT

Product Options: This declaration covers all options of the above product.

Conforms to the following product specifications:

Safety: EN 60950:A2/08.93

EMC: EN 55022:1994, Class A
IEC 801-2:1991 /EN 50082-1:1992, 8 kV CD, 15 kV AD
IEC 801-3:1984 /EN 50082-1:1992, 10 V/m, 27-1000 MHz
IEC-801-4:1988 /EN 50082-1:1992, 1 kV signal, 2 kV ac

Supplementary Information:

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC and the EMC Directive 89/336/EEC.

The XYCOM 3200MT operator interface workstation was tested for EMC compliance as a model 5200MT with the touch screen option installed and as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, U.S.A.

3/7/96



Location

Date

Anthony Joseph Maresh, Jr.
Director Product Engineering

European Contact:

Xycom Europe Ltd., 21 Tentor Road, Moulton Park, Northampton, NN3 6AX England
+44-1604-790-767 (FAX +44-1604-790-722)