

DECLARATION OF CONFORMITY
in accordance with EN 45014:1989

Manufacturers Name: XYCOM Inc.
Manufacturers Address: 750 North Maple Road
Saline, MI 48176
USA.

Declares under our sole responsibility that the product:

Product name: Operator Interface Workstation
Model Number: 9465KPM
Product Options: This declaration covers all options of the above product which bear the CE Marking.

Is in conformity with the following standards or other normative documents:

Low-Voltage Directive 73/23/EEC: EN 60950:1992 + A1:1993 + A2 1993

EMC Directive 89/336/EEC:	EN 55022:1994, Class A	ITE EMI
	EN 50082-2:1995:	Generic industrial immunity
	• EN 61000-4-2:1995	Electrostatic discharge
	• EN 61000-4-3:1996	Radiated RF EM field
	• EN 61000-4-4:1995	Electrical fast transient burst
	• EN 61000-4-8:1993	Power frequency magnetic field
	• ENV 50141:1993	Conducted RF disturbance
	• ENV 50204:1995	900 MHz radio telephone immunity

Supplementary Information:

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC and the EMC Directive 89/336/EEC.

The XYCOM model 9465KPM operator interface workstation was tested for EMC compliance as an apparatus within a system as described in the relevant EMC test files

Saline, Michigan, USA.

2-Mar-98

Location

**Issue
Date**


Anthony Joseph Maresh, Jr.
Director Product Engineering

European Contact:

Xycom Europe Ltd., 21 Tenter Road, Moulton Park, Northampton, NN3 6AX England
+44-1604-790-767 (FAX +44-1604-790-722)